

Licence No: 100

07-07-2025

GSTIN: ABSPV1500H1ZG


**STRUCTURAL SOUNDNESS CERTIFICATE**

Sub: Study of Structural stability and soundness of **S R Digi School**,  
Hindustan Zinc Smelter Post, Gajuwaka, Visakhapatnam.

Ref: Letter from Principal, S R Digi School, Hindustan Zinc Smelter  
Post, Gajuwaka, Visakhapatnam, dated 05-07-2025.

This has been with respect to structural soundness of **S R Digi School**, Hindustan Zinc Smelter Post, Gajuwaka, Visakhapatnam managed by Sarvahitha Educational Society, Visakhapatnam. I have inspected the school building on 06-07-2025 for its stability and soundness. School is running masonry structure with Ground and first floor as per plan submitted by the applicant. School is running in the half portion of Ground floor and entire portion of First floor of the building. Structural drawings/designs for the said building are not made available during my visit. It is reported by the Principal that the existing building was constructed in the year of 1998 and it is about 27 years old.

Adequate staircase facilities are provided in the building. As school building is concerned, all the visible elements of the building such as beams, slabs and brick work are found to be in good condition. There is no visible distress anywhere in the structural components of the building. In the present condition, this **S R Digi School**, Hindustan Zinc Smelter Post, Gajuwaka, Visakhapatnam, is structurally stable and sound to take care of the loads. However, proper maintenance is to be extended continuously. The validity of the certificate is for the period of two years from the date of issue of the certificate.

  
Villa Venkateswara Rao, B.Tech (Civil)/AE 1  
Licenced Structural Engineer, GVMC, VMRDA & VKPCPIR  
D.No. 7-17-1/(1), G-1, Suman Apt.s.  
57/A, Kirlampudi Layout, Vizag-17  
Mob. : 9441195678, 0891-27 45678