



GREATER VISAKHAPATNAM MUNICIPAL CORPORATION
FIRE PREVENTION WING

From: The Commissioner,
Greater Visakhapatnam
Municipal Corporation,
Visakhapatnam.

To: The District Educational Officer,
Visakhapatnam District,
Visakhapatnam.

Rc.No.198/RFO/FPW/GVMC/2025, Dt.14-07-2025

SUB: Greater Visakhapatnam Municipal Corporation – Fire Prevention Wing-
Existing Building of – **M/s.SR DIGI School, Sy.No.419, Hindustan Zinc
Compound, Mulagada(V), Visakhapatnam –Renewal of Fire
No Objection Certificate** – Issued - Regarding.

REF: 1.Letter Rc.No:5041/B2/97 of Director General, A.P.Disaster Response &
Fire Services Department, Dated: 12-03-2010.
2.Delegation orders of the Commissioner, GVMC vide Rc.No.6721/2012/TP.
Sec/G1 Dt:13/09/2019.
3.This office Fire No Objection Certificate for Occupancy issued vide
Rc.No.0076/RFO/FPW/GVMC/021, Dt.03-04-2021.
4.This office Renewal of Fire No Objection Certificate issued vide
Rc.No.272/RFO/FPW/GVMC/2024, Dt.16-07-2024.
5.Application Dt.10-07-2025 of M/s.SR DIGI School, Sy.No.419, Hindustan
Zinc Compound, Mulagada(V), Visakhapatnam for Renewal of Fire No
Objection Certificate.

*** **

It is to inform that vide reference 3^d cited, this office issued Fire No
Objection Certificate for Occupancy was issued to the existing Educational
(School) Building of M/s.SR DIGI School, Sy.No.419, Hindustan Zinc Compound,
Mulagada(V), Visakhapatnam and vide reference 4th cited, the management
obtained Renewal of Fire No Objection Certificate

2) Vide reference 4th cited, an application is received by this office for issuance
of Renewal of Fire No Objection Certificate to the same building.

3) Therefore, the Inspection Committee of Fire Prevention Wing inspected the
premises of M/s.SR DIGI School, Sy.No.419, Hindustan Zinc Compound,
Mulagada(V), Visakhapatnam on 11-07-2024 and submitted the following report.

4) Particulars of The building:

a)	Address of the Premises	M/s.SR Digi School, Sy.No.419, Hindustan Zinc Compound, Mulagada (V), Visakhapatnam
b)	Total Plot Area	22,000.00 Sq. Mtrs.
c)	Height of the Building	7.00 Mtrs.
	No of	

d) blocks/floors	01 / Ground + 01 Upper Floor
e) Type of occupancy	Educational (School)

5) The floor wise details.

Sl. No.	Floor	Area in Sq. Meters.	Type of Occupancy
1.	Ground	1355.00	Educational (School)
2.	First	1355.00	Educational (School)
	Total	2710.00	

6) The Builder has provided the following open places all round building.

Direction	Open space provided (In Mtrs.)
East	06.00
West (Front)	06.00
North	06.00
South	06.00

7) Means Escape:

- The management provided One Internal Staircase and One External Staircase with width of 01.50 Mtrs. each from Ground floor to Terrace.

8) The Minimum Fire Safety Installations required & provided by the Builder.

Sl. No.	Fire Safety Measures	Required	Provided	Deficit
1.	Fire Extinguishers as per IS 2190	28 Nos.	28 Nos.	Nil
2.	Hose Reels	04 Nos.	04 Nos.	Nil
3.	Terrace Tank	10,000 Ltrs.	10,000 Ltrs.	Nil
4.	Booster Pump	450 LPM	450 LPM	Nil
5.	Two way fire brigade inlet	Required	Provided	Nil

10. The management has remitted an amount of Rs.44,038/- vide challan No.2025-CH-03089, Dt.10-07-2025 at Soukaryam counter towards fire precautionary fees and penal interest.
11. The Fire safety systems were tested by the Inspection Committee, Fire Prevention Wing, GVMC during the inspection and performance found satisfactory and recommended for issuance of Renewal of Fire No Objection Certificate.
12. Therefore, **Renewal of Fire No Objection Certificate** is hereby issued to the Educational Building of M/s.SR DIGI School, Sy.No.419, Hindustan Zinc Compound, Mulagada(V), Visakhapatnam subject to the following conditions:

i.	All the protection arrangements shall be maintained in good condition as seen during inspection
----	---

- | | |
|------|--|
| ii. | All the escape / exit routes shall not be kept locked / blocked or encroached |
| iii. | All the occupants must know the correct method of operation of the fire fighting system installed |
| iv. | Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management. |
| v. | All students / staff members of the Institution shall be trained to operate the fire safety equipments during Emergency. |
| vi. | Addition / alteration, if any in the building may be obtained with prior permission from this department. |
| vii. | Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months. |

13) The **Renewal of Fire No Objection Certificate** issued to M/s.SR DIGI School, Sy.No.419, Hindustan Zinc Compound, Mulagada(V), Visakhapatnam is **valid from 03-04-2025 to 02-05-2028** and the Management shall submit the application for Renewal of Fire No Objection Certificate two (2) months before the date of expiry.

14) The issuing of Fire NOC is without any prejudice to take action by GVMC against Unauthorized Construction, if any made.


 (CH.KRUPAVARAM)
 Regional Fire Officer i/c
 Fire Prevention Wing

Greater Visakhapatnam Municipal Corporation
 Visakhapatnam

Copy to:

1. The Management, M/s.SR DIGI School, Sy.No.419, Hindustan Zinc Compound, Mulagada(V), Visakhapatnam.

Digitally signed by
 CHINTADA KRUPAVARAM
 Date: 14-07-2025
 17:23:08